


Corrected
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY



Log No. 108122
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58329

1. OWNER Gary Imelli
 MAILING ADDRESS 3388 Austin Hwy Fallon, NV 89406
 Fallon, NV 89406

ADDRESS AT WELL LOCATION 3322 Austin Hwy
 Fallon, NV 89406

2. LOCATION NE 1/4 NW 1/4 Sec 34 T 19 R 29
 PERMIT NO R-521 Parcel No. 007-911-04

Latitude 39.47402 Longitude -118.71759 WGS 84
 Subdivision Name _____ County Churchill

3. WORK PERFORMED
 New Well

4. PROPOSED USE
 Domestic

5. WELL TYPE
 Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	4	4
Brown Clay		4	6	2
Brown Sand	X	6	38	32

8. WELL CONSTRUCTION

Depth Drilled 38 Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
12.5 Inches	0 Feet	38 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	0	20
6	4.0	0.316	20	38

Perforations:

Type perforation Saw Cut
 Size perforation 0.125
 From 35 feet to 38 feet

Surface Seal Yes No

Seal Type:

Depth of Seal 28

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 28 feet to 38 Feet

9. WATER LEVEL

Static Water Level 5 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road

Fallon, NV 89407

Contracto

Nevada contractor's license number 29064

issued by the State Contractor's

Nevada driller's license number issued by the 2307

Division of Water Resource, the on-site driller

Signe

By driller performing the actual drilling on site or contract

Date 9/2/2008

Date started 8/17/2006

Date completed 8/17/2006

7. WELL TEST DATA

TEST METHOD

*N 39.474119
 W 118.716625 NAD27*

STATE ENGINEER

2008 SEP 26 AM 11:06