WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108146
Permit No.
Basin 212

NOTICE OF INTENT NO. 32226

1. OWNER Bruce Bayne
MAILING ADDRESS 851 S. Rampart Blvd Suite 150, LV. NV. 89145
ADDRESS AT WELL LOCATION 1950 Calico Rd LV. NV.

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 21 N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 164-06-301-008 Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	125	
Brownish Sandstone		125	230	
Greenish Sandstone	X	230	265	
Orange Clay		265	270	
Brown Shale		270	275	
Orange Clay		275	280	
Brown Sandstone		280	500	
Orange Sandstone		500	560	
Brown Sandstone		560	660	
Lime Stone	X	660	770	
Lt. Brown Sandstone		770	780	
Hard Sandstone		780	830	
Blue Clay		830	900	
Brown Sandstone		900	1010	
Grey Lime Stone	X	1010	1020	
Blue Clay		1020	1030	
Lime Stone	X	1030	1040	
N 36° 08' 58" W 115° 25' 00"				

Date started 03-31-09, 20
Date completed 05-06-09, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAY 11 2009

8. WELL CONSTRUCTION
Depth Drilled 1040 Feet Depth Cased 1040 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	110 Feet
9 7/8 Inches	110 Feet	1040 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	110.94
6 1/2	PVC	.480	+1 1/2	1040

Perforations:
Type perforation Drilled
Size perforation 3/8" 4 Times A Round
From 1000 feet to 1040 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 110
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 119 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 5360 N. Bonita Vista St.
Contractor
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 05-11-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627