

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 137B

NOTICE OF INTENT NO 63616

1. OWNER Bruce Clouser ADDRESS AT WELL LOCATION #1 Morris Creek Road, Round Mt NV 89045  
MAILING ADDRESS HC 60 Box 52530 Round Mountain NV 89045  
2. LOCATION NE 1/4 SE 1/4 Sec. 26 T. 12 R. 44 E. NYE County  
PERMIT NO. 28-131-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Boulders		0	50	50
Hard Clay		50	110	60
Sand Boulders	X	110	122	12
Hard Rock		122	126	4

Customer plans on using a solar pump, so this well should produce plenty of water

WGS 804  
N 38° 52.071'  
W 116° 59.958'

2009 MAR - 9 PM 11:45 AM

N 38.967926  
W 116.998381 NAD27

8. WELL CONSTRUCTION  
Depth Drilled 126 Feet Depth Cased 126 Feet  
HOLE DIAMETER (BIT SIZE)  
From 11 Inches To 0 Feet 126 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>126</u>

Perforations:  
Type perforation saw cut  
Size perforation 1 1/8" V 3"  
From 106 feet to 126 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 126 feet

9. WATER LEVEL  
Static water level 67 feet below land surface  
Artesian flow 6 G.P.M. P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address HC 61 Box 54 Hiko NV 89017 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0028266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed M. Dai  
By driller performing actual drilling on site or contractor  
Date 2-20-09

Date started 2-14-09, 20  
Date completed 2-19-09, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>	<u>25</u>	<u>1</u>