WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108209
Permit No.
Basin 162

NOTICE OF INTENT NO. 33085

1. OWNER Fernando, Zenon & Myra Lopez
MAILING ADDRESS 821 W. Betty
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
791 W. Betty 36D 09.900N 115D58.300W NAD 83/WGS 84

2. LOCATION NW 1/4 SW 1/4 Sec. 9 T 20S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources | 35-173-09 Parcel No. | Cal-Vegas Ranchos Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown loam | x | 0 | 98 | 98 |
| See next line | x | 98 | 200 | 102 |
| brown loam with caleche strings | | | | |

DCNR/DWR RECEIVED
MAY 28 2009
LAS VEGAS OFFICE

Date started 5/21/1909 2009, 19__
Date completed 5/21/1909 2009, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 11 | Inches | 0 | Feet | 200 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.7 | .280 | 0 | 200 |
| | | | | |

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] By driller performing actual drilling on-site or contractor
Date 5-27-09