STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108226
Permit No.
Basin 131

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61076

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION Phoenix Mine
Hole #CM-9B
Subdivision Name: County: Lander

2. LOCATION SE ¼ SE ¼ Sec. 16 T 30N N/S R 43 E
PERMIT/WAIVER No. NEV00870611
Issued by Water Resources Parcel No.

Latitude 40.467048 Longitude 117.135885
UTM E 488480 N 4479395
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [x] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	75	75
Clay		75	95	20
Alluvium		95	120	25
Clay		120	130	10

Date started: 5-Feb , 20 09
Date completed: 6-Feb , 20 09

9. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	130	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2		Sch 80 PVC	+2	98
4 1/2		Sch 80 PVC Screen	98	118
4 1/2		Sch 80 PVC	118	128

Perforations:
Type of perforation Factory Slot
Size of perforation 0.02
From 98 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 10 to 0 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 130 to 95 [x] Pumped [ ] Poured
Type: #8 Silica Sand
Bentonite Chips: [x] Yes [ ] No 95 to 10 [ ] Pumped [x] Poured
Type: 3/8" Hole Plug

7. Water Level
Static water level: 27 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
43		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2384
Signed Shawn Mikelson by MB
By driller performing actual drilling on site or contractor
Date 2/6/2009

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY