

OFFICE USE ONLY 108233
Log No. _____
Permit No. _____
Basin. 037

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57756

1. OWNER Anglo Gold Ashanti (Nevada) Corp. ADDRESS AT WELL LOCATION Doheny ranch 60 miles north of ELKO Nev. on CR 732 off SR-225
MAILING ADDRESS 460 W. Silver St. Suite 106 N 41.574460 W 15.875509 NAD83
ELKO, NV. 89801
2. LOCATION SW 1/4 SE 1/4 Sec. 34 T. 43 S. R. 54 ELKO County
PERMIT NO. BMREW PCP NEV0087001 (APN) 05-600-006 Subdivision Name _____
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill out PVC				
Dual set to 100'				
mix & Pump				
Pump 5-50 LB.				
Bags of Super				
Plug T.D. 10'				
Pour 4 Bags 1/2"				
Hole plug				
Cement Top 10'				

2008 AUG 22 AM 11:30
STATE DEPARTMENT OF PUBLIC UTILITIES
UTM E: 593670
UTM N: 4603130
NAD 83/WGS84

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From 6 Inches To 98' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
Dual set 2 .698 Sch. 40 PVC 0' 98'
Perforations:
Type perforation _____
Size perforation _____
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal: 10' Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet
9. WATER LEVEL
Static water level: 73.9 feet below land surface
Artesian flow: N.D. G.P.M. 2 P.S.I.
Water temperature: 46° F Quality: clear

Date started: 8-17-08 2008
Date completed: 8-17-08 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Ward Weaver Contractor
Address: 2305 Last Chance Rd Contractor
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board: 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1676
Signed: Ward Weaver
By driller performing actual drilling on site or contractor
Date: 8-18-08