WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

13

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108234
Permit No.
Basin Ø37

NOTICE OF INTENT NO. 57762

1. OWNER AngloGold Ashanti (Nevada) Corp.
MAILING ADDRESS 460 W. Silver St. Suite 106
ELKO, NV. 89801

ADDRESS AT WELL LOCATION Doheny ranch 60 miles north of ELKO, Nev. on CR 732 off SR-225
N41.573279 W115.874450 NAD27

2. LOCATION SE ¼ SE ¼ Sec. 34 T. 43 N S R. 54 E ELKO County
PERMIT NO. BMRRWPCP NEV0087001 (APN) 05-600-006
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill out PVC Dual set to 110'.				
mix & pump 5-50LB. Bags of Super plug T.D. UP.				
Place 6 Bags 3/8" Hole plug & cement off Top 10?				
	UTM E: 593760			
	UTM N: 4603000			
	NAD83/WGS84			

RECEIVED 2008 AUG 22 AM 11:30 STATE ENGINEERS OFFICE

Date started 8-17-, 2008
Date completed 8-17-, 2008

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2009 JAN -5 AM 11:24

8. WELL CONSTRUCTION

Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0' Feet	110' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Dual Set 2"	.698	Sch. 40 PVC	0'	110'

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 56' feet below land surface
Artesian flow NO G.P.M. 2 P.S.I.
Water temperature 46° °F Quality Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ward Weaver
Contractor
Address 2305 Last Chance Rd
Contractor
ELKO, NV. 89801

Nevada contractor's license number issued by the State Contractor's Board 0030630

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676

Signed Ward Weaver
By driller performing actual drilling on site or contractor

Date 8-18-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627