13A

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108236
Permit No.
Basin Ø37

NOTICE OF INTENT NO. 57757

1. OWNER Anglo Gold Ashanti (Nevada) Corp.
MAILING ADDRESS 460 W. Silver St. Suite 106
ELKO, NV. 89801

ADDRESS AT WELL LOCATION Doheny ranch 60 miles North of ELKO, NV. on CR 732 off SR-225
N41.573279 W115.974450 NAD27

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 43 N S R. 54 E ELKO County
PERMIT NO. BMRRWPCPNEY0087001 (APN) 05-600-006
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels & Clay		0'	110'	
water at	60'			
Flush Joint Sch. 80 PVC				
Gravel Pack & 3/8" Hole plug & → 5'-60' Cement.				
		UTM	E: 593760	
		UTM	N: 4603000	
	NAD 83/WGS 84			

2008 AUG 22 AM 11:30

Date started 8-16- , 2008
Date complated 8-16- , 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2009 JAN -5 AM 11:24

8. WELL CONSTRUCTION
Depth Drilled 110' Feet Depth Cased 110' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0' Feet	110' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	.698	Sch. 80 PVC	0'	110'

Perforations:
Type perforation Horz. slot
Size perforation .02
From 110' feet to 90' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 110' feet to 60' feet

9. WATER LEVEL
Static water level 61.2 feet below land surface
Artesian flow NO G.P.M. 2 P.S.I.
Water temperature 46° °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver
Contractor
Address 2305 Last Chance Rd
Contractor
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver
By driller performing actual drilling on site or contractor
Date 8-18-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627