

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 108242
Permit No. 64855
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62597

1. OWNER Titan Constructors, Inc. ADDRESS AT WELL LOCATION 7 miles No. of Ely
MAILING ADDRESS P.O. Box 151191 us hwy 93.
Ely, NV 89315 Subdivision Name: N/A County: White Pine

2. LOCATION SW 1/4 NE 1/4 Sec 18 T17N N3R 64 E Latitude UTM KXXXXXXX NAD 27
PERMIT/WAIVER No. 64855 #010-320-03 Longitude N 4356564 NAD 83/WGS 84
Parcel No. E 11#0688399,

3. WORKED PERFORMED New Well Replace Recondition Deepen Other

4. PROPOSED USE Domestic Irrigation Test Stock Municipal/Industrial Monitor

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt		0	2	2
sand/gravel		2	13	11
clay		13	16	3
sand/gravel		16	187	171
clay		187	200	13

9. WELL CONSTRUCTION

Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>24"</u> Inches	<u>0</u> Feet	<u>200'</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>18"</u>		<u>.250</u>	<u>0</u>	<u>200'</u>

Perforations:

Type of perforation torch
Size of perforation 3/16" #4 slot 16 rows

From 60' feet to 180' feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 5' to 55' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 55' to 200' Pumped Poured
Type: 3/8" natural round pea gravel
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

N 39,35964
W 114,813962
NAD 27

Date started: may 19, 2008
Date completed: feb. 27, 2009

7. Water Level

Static water level: 57' feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: cool °F
Quality: Good

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3000</u>	<u>72</u>	<u>48</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Titan Constructors, Inc.
Address P.O. Box 151191 Ely, NV 89315
Contractor

Nevada contractor's license number #0066632 A / 30630
issued by the State Contractor's Board
Nevada driller's license number issued by the #2251
Division of Water Resources, the on-site driller

Signed [Signature]
By driller performing actual drilling on site or contractor
Date March 19, 2009

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY