STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108250
Permit No.
Basin 212

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 32246

1. OWNER CV Propco LLC
MAILING ADDRESS 4530 Polaris Ave.
Las Vegas, NV, 89103

ADDRESS AT WELL LOCATION Same as Owner
MW-15
Subdivision Name: County: clark

2. LOCATION NE ¼ SW ¼ Sec 20 T 20S N/S R 61 E
PERMIT/WAIVER No. 162-20-302-001
Issued by Water Resources Parcel No.

Latitude 36 10936
Longitude 115 18464
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 2 | 2 |
| Silty Sand | | 2 | 6 | 4 |
| Sandy Clay | | 6 | 10 | 4 |
| Caliche | | 10 | 11 | 1 |
| Clayey Sand | x | 11 | 14 | 3 |
| Sandy Clay | | 14 | 27 | 13 |

Date started: 13-May, 20 09
Date completed: 13-May, 20 09

DCNR/DWR RECEIVED MAY 18 2009 LAS VEGAS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 27 Feet Depth Cased 26 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 27 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | 2.06 | Sch 40 | 0 | 26 |

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 11 feet to 26 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 9 to 27 [ ] Pumped [X] Poured
Type: # 3 Silica
Bentonite Chips: [X] Yes [ ] No 2 to 9 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| N/A | | | |

DCNR/DWR RECEIVED MAY 19 2009 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells (Contractor)
Address 570 corinthian way (Contractor)
N Las Vegas 89030
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 5-19-09

(Rev. 05-06)

**USE ADDITIONAL SHEETS IF NECESSARY**