

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. **108254**
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **32247**

1. OWNER CV Propco LLC ADDRESS AT WELL LOCATION Same as Owner
MAILING ADDRESS 4580 Polaris Ave
Las Vegas, NV, 89103 Subdivision Name: _____ County: clark

2. LOCATION NE 1/4 SW 1/4 Sec 20 T 21s N/S R 61 E Latitude 36 11069 UTM E NAD 27
PERMIT/WAIVER No. 162-20-302-008 Longitude 115 18468 N NAD 83/WGS 84
issued by Water Resources Parcel No. _____

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Other auger

| 6. LITHOLOGIC LOG | | | | |
|-----------------------------------|--------------|------|----|------------|
| Material | Water Strata | From | To | Thick-ness |
| Fill | | 0 | 3 | 3 |
| Silty Sand | | 3 | 7 | 4 |
| Sandy Clay w/thin cemented layers | x | 7 | 22 | 15 |
| Clayey Sand | | 22 | 25 | 3 |
| Sandy Clay | | 25 | 26 | 1 |

| 9. WELL CONSTRUCTION | | | | |
|--------------------------|---------------------|-------------------------|-------------|-----------|
| Depth Drilled | 27 | Feet | Depth Cased | 26 |
| HOLE DIAMETER (BIT SIZE) | | | | |
| | From | To | | |
| | 10 | 0 | 27 | Feet |
| | | | | Feet |
| | | | | Feet |
| CASING SCHEDULE | | | | |
| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
| 4.5 | 2.06 | Sch 40 | 0 | 26 |

DCNR/DWR RECEIVED
 MAY 18 2009
LAS VEGAS OFFICE

Perforations: Type of perforation factory slotted
Size of perforation .020
From 11 feet to 26 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 9 to 27 Pumped Poured
Type: # 3 Silica

Bentonite Chips: Yes No 2 to 9 Pumped Poured
Type: 3/8 chips

7. Water Level
Static water level: 18 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

| 8. WELL TEST DATA | | | |
|---|--------|-------------------------------|--------------|
| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| N/A | | | |

DCNR/DWR RECEIVED
 MAY 19 2009
LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & wells
Contractor
Address 570 corinthian way
Contractor
N Las Vegas 89030
Nevada contractor's license number 0012852
issued by the State Contractor's Board
Nevada driller's license number issued by the M2381
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5-19-09