STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108276
Permit No.
Basin 076

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62822

1. OWNER PILOT TRAVEL CENTERS LLC.
MAILING ADDRESS PO BOX 10146
NE KNOXVILLE, TN. 37939-0146

ADDRESS AT WELL LOCATION 5625 W. I 80 WINNEMUCCA,NV.
Subdivision Name: County: Humboldt

2. LOCATION ~~SE~~ ¼ ~~SW~~ NW ¼ Sec. 10 T 35N N/S R 37 E
PERMIT/WAIVER No. 5-000212 013-081-04
Issued by Water Resources Parcel No.

Latitude N40.93084' Longitude W117.80558'
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT	NO	0	.10	1
SAND/GRAVEL	NO	.10	1.5	1
SAND	NO	1.5	4	3
SILTY/SAND	NO	4	10.5	7
SAND	YES	10.5	25	15

40.930937°N
117.804615°W
NAD27

Date started: 26-Mar, 20 09
Date completed: 26-Mar, 20 09

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH. 40	0	25

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 2 ☐ Pumped ☒ Poured
☒ ≥30% Bentonite ~~Grout~~ Chips 2 to 8 ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 8 to 25 ☐ Pumped ☒ Poured
Type: 10/20 SILICA SAND
Bentonite Chips: ☒ Yes ☐ No 2 to 8 ☐ Pumped ☒ Poured
Type: 3/4 BENTONITE CHIPS

7. Water Level
Static water level: 13.9 feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: <85 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ TECH DRILLING, INC. (Contractor)
Address PO BOX 940 (Contractor)
MERIDIAN, ID. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2246
Signed (By driller performing actual drilling on site or contractor)
Date 3/30/2009

RECEIVED 2009 MAY -1 AM 11:02 STATE ENGINEER'S OFFICE

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY