

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 084

NOTICE OF INTENT NO. 53001

1. OWNER Kim Carbett ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4800 Grassvalley Rd 4800 Grassvalley Rd
WCTY
 2. LOCATION SW 1/4 NE 1/4 Sec. 16 T. 22 S. R. 21 E. Washoe County _____
 PERMIT NO. 077-130-21 Parcel No. _____ Subdivision Name Palomino Valley

3. WORK PERFORMED Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Sandy clay		2	18	16
Clay		18	26	8
Sand		26	45	19
Clay		45	70	25
Sand		70	90	20
Clay		90	98	8
Sand		98	135	47
Clay		135	164	9
Sand		164	275	111
Clay		275	345	70
Sand		345	380	35
Sand & Clay layers		380	562	182

~~N. 39.91505~~
~~W. 119.62923~~
 N. 39.77499
 W. 119.63020

MA027 DD
 39.775°N
 119.629°W

8. WELL CONSTRUCTION
 Depth Drilled 562 Feet Depth Cased 562 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 17 Feet
18 Inches 0 Feet 17 Feet
11 Inches 17 Feet 562 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>562</u>

Perforations:
 Type perforation 3/16 Saw slot
 Size perforation 3/16 6 Around
 From 522 feet to 362 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 562 feet

9. WATER LEVEL
 Static water level 255 feet below land surface
 Artesian flow No G.P.M. NA P.S.I.
 Water temperature 56 °F Quality NA

Date started 10/15, 2007
 Date completed 12/7, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>90</u>	<u>170</u>	<u>440</u>
		<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olenki Drilling & Pump Co.
 Address 15045 Red Rock Rd.
Reno NV 89508
 Nevada contractor's license number 50343
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed Jh F Olenki
 By Driller performing actual drilling on site or contractor
 Date 12/20/07