STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108326
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63485

1. OWNER Washoe County
MAILING ADDRESS 4930 Energy Way
Reno, NV 89502

ADDRESS AT WELL LOCATION Glendale Ave 200 ft E of HWY 395
Reno, NV
Subdivision Name: CMT-83 County: Washoe

2. LOCATION NE ¼ SW ¼ Sec 7 T 19N N/S R 20 E
PERMIT/WAIVER No. MO1517 (Issued by Water Resources) Parcel No.

Latitude
Longitude
UTM E 260865 N 4378790
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [x] Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbly gravel		0	10	10
Brown gravely sand		10	75	65
Brown silty sand w/gravel		75	109	34
Brown silty clay		109	115	6
Brown gravely sand		115	136	21
Grey clay		136	139	3
Grey clayey silt		139	145	6
Brown gravely sand		145	172	27
Brown cobbly gravlely sand		172	189	17
Brown sandy gravel		189	235	46
Brown gravely sand		235	296	61
Bentonite chips		288.5	296	8

39. 527,372°N NAD27
119.782,127°W

Date started: 28-Oct, 20 08
Date completed: 31-Oct, 20 08

9. WELL CONSTRUCTION
Depth Drilled 296 Feet Depth Cased 286.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	296	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 80 PVC	266.5	-.5

Perforations:
Type of perforation Factory cut
Size of perforation .020
From 286.5 feet to 266.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 100 to 1 [x] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[x] ≥30% Bentonite Grout 261 to 100 [x] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 288 to 265 [ ] Pumped [x] Poured
Type: 2/12
Bentonite Chips: [ ] Yes [x] No 261 to 265 [ ] Pumped [x] Poured
Type: Pure gold 3/8 chips

7. Water Level
Static water level: 31.91 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 54.2 °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [x] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	3		1.75

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address PO Box 141 (Contractor)
Zamora, CA 95698
Nevada contractor's license number issued by the *State Contractor's Board* 12852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* T2111
Signed (By driller performing actual drilling on site or contractor)
Date 10/31/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY