

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY 108333

Log No. _____
Permit No. _____
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63492

1. OWNER Washoe County ADDRESS AT WELL LOCATION Gentry Way 280 E of Neil Rd.
MAILING ADDRESS 4930 Energy Way Reno, NV
Reno, NV 89502 Subdivision Name: CTM-90 County: Washoe

2. LOCATION NE ¼ SW ¼ Sec 19 T 19N N/S R 20 E Latitude UTM E 261053 NAD 27
PERMIT/WAIVER No. MO 1517 Longitude N 4375185 NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED New Well Replace Recondition
 Deepen Other

4. PROPOSED USE Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Medium sand		0	15	15
Gravelly sand		15	17	2
Silty sand		17	21	4
Silty sand w/gravel		21	32	11
Coarse sand		32	65	33
Sand w/silt		65	72	7
Gravelly sand		72	140	68
<u>29. 494, 979° W NAD 83</u>				
<u>119. 778, 649° W</u>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
140		140	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
6	0	140	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 80 PVC	0	120

Perforations:

Type of perforation	Mill Slot
Size of perforation	.020
From 140 feet to 120 feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	

Annular Seal: Yes No

<input checked="" type="checkbox"/> Neat Cement	0 to 116	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 118 to 140 Pumped Poured
Type: Cemex 2/12 sand 4bg-110lb

Bentonite Chips: Yes No 112 to 118 Pumped Poured
Type: Pure gold medium chips

Date started: 3-Oct 20 08
Date completed: 4-Oct 20 08

7. Water Level
Static water level: 7.47 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 68.1 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	3		4

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells
Contractor

Address PO Box 141
Contractor

Zamora, CA 95698

Nevada contractor's license number _____
issued by the State Contractor's Board 12852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller T2111

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 10/4/2008