

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 106

NOTICE OF INTENT NO. 61870

1. OWNER Topaz Ranch Estates G.I.D. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Wellington NV. 89444 3939 Carter Dr. Wellington NV. 89444
 2. LOCATION NE 1/4 SW 1/4 Sec 15 T 10 R 22 E Douglas County
 PERMIT NO. 41205 Issued by Water Resources Parcel No. 0022-15-001-11 Subdivision Name Topaz Ranch ESTs.
 Old Well

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Old 8" Well open To bottom 200'				
Perf from 160' To 20'				
Pump neat cement and bentonite mix from bottom To 20' from surface				
Pump neat cement 20' To surface				
NAD 27 38 43 58.7 119 29 52.6				
38.732972° N 119.497944° W NAD 27				
This log plugging well log 22278 (TA)				
Date started <u>7/23</u> , 20 <u>09</u>				
Date completed <u>7/24</u> , 20 <u>09</u>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 112.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olenki Drilling & Pump Co. Contractor
 Address 15045 Red Rock Rd Reno NV. 89506 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 50343
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Olenki
 By driller performing actual drilling on site or contractor
 Date 8/3/09

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)