STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108420
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64355

1. OWNER Fortino Rodreguez Carrillo
MAILING ADDRESS 296 Meadow Valley Ranch #14
Elko, NV 89801

ADDRESS AT WELL LOCATION 253 Trescartes Ave
Subdivision Name: County: Elko

2. LOCATION NE ¼ ~~SE~~ SW ¼ Sec 34 T 34N N/S R 56 E
PERMIT/WAIVER No. 038-002-012
Issued by Water Resources Parcel No.

Latitude 40.47.09N
Longitude 115.39.15W
UTM E N NAD83
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandstone		0	35	35
Sand/Gravel		35	80	45
Fine Gravel/Sand	X	80	160	80

40.784909°N
115.651602°W
NAD 27 (Tol)

Date started: 24-Jun , 20 09
Date completed: 25-Jun , 20 09

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.188	+2	160

Perforations:
Type of perforation Machine
Size of perforation 14" x 4"
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 15 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type: 3/8" pea gravel
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☐ Poured
Type: 3/8 chips

7. Water Level
Static water level: 45 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	40		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel "Clay" Fertig Jr., dba Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, Nv 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2367
Signed (By driller performing actual drilling on site or contractor)
Date 7-20-09

(Rev 05-05)

USE ADDITIONAL SHEETS IF NECESSARY