

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108433
Permit No. _____
Basin 777

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64359

1. OWNER Victoria Bond - BBK Land & Cattle Co. ADDRESS AT WELL LOCATION South of Wells, NV
MAILING ADDRESS 10346 South Grayrock
Sandy, UT 84092 Subdivision Name: _____ County: Elko

2. LOCATION SE 1/4 NW 1/4 Sec 13 T 36N N/S R 62 E Latitude 41.00.22N UTM E NAD 27
PERMIT/WAIVER No. 008-330-015 Longitude 114.55.05W N NAD83 NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	4	4
Limestone		4	90	86
Sandy Clay		90	100	10
Limestone		100	210	110
Sandy Clay		210	215	5
Sandstone		215	280	65
Conglomerate		280	440	160
Sandstone	X	440	460	20
Limestone		460	485	25
Sandstone	X	485	540	55
Sandy Gravel	X	540	660	120
Limestone		660	665	5

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
665		665	

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
10 3/4	0	50	50	
8 3/4	50	665	665	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	620
6 5/8		.188	660	665

41.003743°N
114.916623°W
NAD 83

Perforations:

Type of perforation Machine Slot
Size of perforation 3/16" x 4"

From	feet to	feet to	feet to	feet to
620	660			

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout 0 to 20 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 50 to 665 Pumped Poured
Type: 3/8 clean

Bentonite Chips: Yes No 20 to 50 Pumped Poured
Type: 3/8 Ships

Date started: 31-Jul, 2009
Date completed: 3-Aug, 2009

7. Water Level 489 feet below land surface
Static water level:
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	15	560	8

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Clay Fertig dba Fertig Drilling Company
Contractor
Address P.O. Box 525
Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2367

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 08-25-09