WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108453
Permit No.
Basin 049

NOTICE OF INTENT NO. 64024

1. OWNER ALLEN Levie
MAILING ADDRESS 162 Kitridge Canyon Unit 2
ADDRESS AT WELL LOCATION Corner of Statice & Powhaten Units Lot 5 ELKO, NV. NAD-27 11T060-5630E 452-4896 N

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 35 N R. 55 E ELKO County
PERMIT NO. Issued by Water Resources
037-063-005 Parcel No.
Meadow Valley Ranchos Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0'	3'	3'
Gravely Clay		3'	85'	82'
moderate Gravels		85'	200'	115'
Fine Gravels		200'	300'	100'
	40.870236°N			
	115.746522°W			
	NAD27			
First water	200'			
more water	220'			
13 GPM	240'			
30 GPM	260'			
40 GPM	300'			
Gravel Pack - 50 to 290'				
3/8" Bentonite chips 50 to 25'				
Neat Cement 25' to -4'				

RECEIVED 2009 SEP -4 AM 11:02 STATE ENGINEERS OFFICE

Date started 8-29, 2009
Date completed 8-31, 2009

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		4

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 290' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0' Feet	20' Feet
10 5/8 Inches		20' Feet	300' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	250'
6.625	13	.188 Perf	250'	290'

Perforations:
Type perforation 6 Row Perf.
Size perforation 3/16 x 3"
From feet to feet
From 250' feet to 290' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal -4 to 25'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 290' feet

9. WATER LEVEL
Static water level 204' feet below land surface
Artesian flow NO 40 G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver - Rimrock Drilling Contractor
Address 2305 Last Chance Rd. Contractor
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver By driller performing actual drilling on site or contractor
Date 9-1-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627