STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108462
Permit No.
Basin 181

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64506

1. OWNER Frank McCluen
MAILING ADDRESS 4435 Hawk Drive
Fallon, NV 89406

ADDRESS AT WELL LOCATION 6031 Cow Canyon Rd
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION NW¼NW¼ Sec27T18N/ R28E
PERMIT/WAIVER NO. 006-541-49
Issued by Water Resources Parcel. No.

Latitude 39.40191N UTM E ☐ NAD 27
Longitude -118.83583# N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
brown Clay		6	12	6
Gravel		12	18	6
brown Clay		18	23	5
Gray Clay		23	28	5
Black & Gray Clay		28	52	24
Black & Gray Sand		52	74	22
Green Clay		74	79	5
black & Gray Gravel		79	109	30
gray Clay		109	128	19
Black & Gray Gravel		128	173	45
gray Clay		173	194	21
Green Clay		194	214	20
gray Clay		214	221	7
Black & Gray Sand & Gravel		221	240	19
39.401962°N				
118.834844°W NAD 27				
Plugged by NOI 64506				

Date started: 8/14, 20 09
Date completed: 8/14, 20 09

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED 2009 SEP -8 PM 1:35 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.25 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2285
Signed
By driller performing actual drilling on site or contractor
Date 8/21/09

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com