

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 108525
 Permit No. 23704
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33171

1. OWNER PAHRUMP MOBILE HOME PARK
 MAILING ADDRESS 680 S EAST ST.
 PAHRUMP, NV ADDRESS AT WELL LOCATION 680 S EAST ST.

2. LOCATION NW 1/4 SW 1/4 Sec. 14 T 20S N/S R 53E E NYE County
 PERMIT NO. 23704 & 34644 35-303-01 RAYCRAFT
Issued by Water Resources Parcel No. Subdivision Name

RKD

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other PLUG
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
N 36° 12.564				
W 115° 59.553				
WAIVER # R-1410				
PERMIT # 23704				
EXISTING 8" STEEL WELL				
PUMP BENTONITE GROUT FROM, 250 FT. TO 160FT. USED 120 CUBIC FT. OF BENTONITE GROUT. PUMP NEAT CEMENT FROM 60 FT TO 10 FT. USED 78 CUBIC FT OF NEAT. INSTALL 10 FT. CONCRETE PLUG ON TOP				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 EXST 8" inches From _____ Feet To _____ Feet
 inches _____ Feet _____ Feet
 inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXST 8"				

 Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 Surface Seal: Yes No
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
of Bentonite

Date started 7/7/2009 19
 Date completed 7/7/2009 19

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E MANSE RD Contractor
 PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller, 1426
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date 7/9/2009

DCNR/DWR
 RECEIVED
 JUL 18 2009
 LAS VEGAS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY