

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33183

1. OWNER JOE NAVARRO
 MAILING ADDRESS 2080 S RIVER PLATE DR.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2080 S RIVER PLATE

2. LOCATION NE 1/4 NE 1/4 Sec. 29 T 20S
 PERMIT NO. 39-051-07
Issued by Water Resources Parcel No.

N/S R 53E E NYE County
CALVADA VALLEY UNIT 8B
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING 8" STEEL WELL		0	140	140
XLAY		140	165	25
CALICHE	WB	165	170	5
CLAY		170	188	18
CALICHE	WB	188	195	7
CLAY		195	220	25
CALICHE	WB	220	235	15
CLAY		235	250	15
CALICHE	WB	250	262	12
CLAY		262	280	18

N 36° 11' 22.9"
 W 116° 02' 01.5"
 WELL LOG # 48619

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From	To	Feet	Feet
EXT 8"		0	140		
7 7/8		140	280		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXT 8 5/8	16.94	.188	0	140
4.5	2.06	.248	140	280

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8 X 3
 From 180 feet to 280 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 280 feet

9. WATER LEVEL
 Static water level 76 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
 Address 1220 E MANSE RD
Contractor

PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 8/5/2009

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
 RECEIVED

AUG 07 2009

LAS VEGAS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY