COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108560
Permit No. 77416
Basin 212

NOTICE OF INTENT NO. 33998

1. OWNER CHELSEA N N B A L L C
MAILING ADDRESS 10724 Wilshire Blvd #1203
Los Angeles, CA 90024-4473

ADDRESS AT WELL LOCATION S. Las Vegas Blvd
Las Vegas, NV

2. LOCATION NE ¼ NE ¼ Sec 17 T 23 S R 61 E CLARK County

PERMIT NO. 77416 (Issued by Water Resources) 191-17-501-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aluvium		0	80	80
Cemented conglomerate w/ lenses of sand & gravel.		80	125	45
Cemented conglomerate with lenses of silt & clay.		125	230	105
Cemented conglomerate.		230	292	62
Cemented conglomerate with lenses of limestone.	x	292	463	171
Cemented conglomerate with lenses of sand stone.	x	463	528	65
Cemented conglomerate with gravel lenses.	x	528	554	26
Limestone		554	607	53

WGS84
N35 57. 174'
W115 10. 562'

35.952907°N
115.175199°W NAD27 (TA)

DCNR/DWR
RECEIVED
AUG 20 2009
LAS VEGAS OFFICE

Date started August 6, 20 09
Date completed August 14, 20 09

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	50	unknown	1 hour

8. WELL CONSTRUCTION

Depth Drilled 607 Feet Depth Cased 607 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	607 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		sch40 IB	+4	607

Perforations:
Type perforation machine
Size perforation .032
From 547 feet to 587 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60' ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 382 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed Victor Esla
By driller performing actual drilling on site or contractor
Date August 17, 2009

RECEIVED
2009 SEP 21 AM 8:56
STATE ENGINEERS OFFICE