STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108564
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32249

1. OWNER Trident Trust LP & Downer family Partnership
MAILING ADDRESS 30240 Rancho viejo rd #b;
San Juan Capistrano, Ca 92675

ADDRESS AT WELL LOCATION 1255 S Lamb Blvd
EW-4 Las Vegas, NV
Subdivision Name: County: clark

2. LOCATION NW ¼ NW ¼ Sec 5 T 21S N/S R 62 E
PERMIT/WAIVER No. 161-05-110-003
Issued by Water Resources Parcel No.

Latitude 36.9'29.54" UTM E [X] NAD 27
Longitude 115.04'52.98" N [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Clayey Silt		2	6	4
Silty Clay		6	20	14
Silty Clay w/ coarse sand		20	25	5

DRILLER'S RECEIVED JUN 25 2009 LAS VEGAS OFFICE

Date started: 29-May, 20 09
Date completed: 29-May, 20 09

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	25

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 8 to 25 [ ] Pumped [X] Poured
Type: Montery# 3 Silica
Bentonite Chips: [X] Yes [ ] No 1 to 8 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 13.5 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells
Contractor
Address 570 corinthian way
Contractor
N Las Vegas 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ M2381
Signed
By driller performing actual drilling on site or contractor
Date 6-23-09

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY