COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108614
Permit No.
Basin 212

NOTICE OF INTENT NO. 33993

1. OWNER **Perini Building Compnay Inc.**
MAILING ADDRESS **360 E. Coronado**
Phoenix, AZ 85004-1524

ADDRESS AT WELL LOCATION **Duck Creek Wash-Paradise**
sw corner of Patrick Lane and Green Valley Pkwy
Henderson, NV

2. LOCATION **NE** ¼ **SE** ¼ Sec **31** T **21** S R **62** E **CLARK** County

PERMIT NO. **DW1294** (Issued by Water Resources) **161-31-702-024** (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other **Auger**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1-40' Dewater well				
Brown silty dirt		**0**	**4'**	**4'**
Gray silt	**xx**	**4'**	**34'**	**30'**
Tan clay		**34'**	**40'**	**6'**
WGS84				
N36. 04. 583'				
W115 05. 042'				

DCNR/DWR
RECEIVED
AUG 21 2009
LAS VEGAS OFFICE

Date started **July 22**, 20 **09**
Date completed **July 22**, 20 **09**

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled **0** Feet Depth Cased **40** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	**0** Feet	**40** Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"		**1/4"**	**0**	**40**

Perforations:
Type perforation **machine cut**
Size perforation **1/4"**
From **20** feet to **40** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From **0** feet to **40** feet

9. WATER LEVEL
Static water level **4** feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **ALLEN DRILLING INC.** (CONTRACTOR)
Address **4015 WEST TOMPKINS AVE.** (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board **0018916 & 0018917**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **ABDS2161**
Signed
By driller performing actual drilling on site or contractor
Date **August 17, 2009**

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com