WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 108637
Log No.
Permit No.
Basin 179 (A)

NOTICE OF INTENT NO. 62632

1. OWNER Ray Mosier
MAILING ADDRESS P.O. Box 1444 McGill NV 89318
ADDRESS AT WELL LOCATION 20 Miles N of McGill NV on Hwy 93

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 21 N/S R. 64 E White Pine County
PERMIT NO. 26489, 26631, 27084 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ PVC
☐ Air ☐ Other NA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Re-Perf | | | | |
| 50-120' | | | | |
| 39.640314°N | | | | |
| 114.781612°W | | | | |
| NAD 27 (FA) | | | | |
| Reconditioning NOI #62629 | | | | |

Date started 8/2/04, 20
Date completed 8/3/04, 20

RECEIVED 2009 SEP -2 AM 8:59 STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| approx | 750-1000 | |
| (C) | 11 hrs | |

8. WELL CONSTRUCTION
Depth Drilled NA Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| NA Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 16. | 42 | .250 | 1 | 360 |
| | | | | |

Perforations:
Type perforation Holt Rail Perf
Size perforation 1.5 x 18 x 6 x 8# Rows
From 50 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal NA
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address P.O. Box 799 Contractor
Gila Bend NV
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18716
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/26/09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627