STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108659
Permit No.
Basin 175

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61096

1. OWNER Bald Mountain Mine
MAILING ADDRESS PO Box 5279
Elko, NV 89802

ADDRESS AT WELL LOCATION Bald Mountain
MW-02
Subdivision Name: County: White Pine

2. LOCATION SW ¼ SW ¼ Sec 29 T 24N N/S R 58 E
PERMIT/WAIVER No. NEV0098100
Issued by Water Resources Parcel No.

Latitude 39 55'03.27"N
Longitude 115 28"27.33"W
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium	Yes	0	390	390
4" - 1/4" Blank Steel Casing		0	290	290
4" - 1/4" Slotted Steel Casing		290	350	60
4" blank 1/4" Wall Steel Casing		350	390	40
Neat Cement		0	20	20
Cement Bentonite Grout		20	270	250
Bensand Grout		270	288	18
1/4" Gravel		288	390	102

39.917575°N
115.474258°W
NAD27
TA

Date started: 6-May, 20 09
Date completed: 8-May, 20 09

9. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
16	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	390	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		1/4" steel Casing		
4		1/4" Steel Casing		

Perforations:
Type of perforation Slotted
Size of perforation 1/8"
From 290 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 20 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 390 to 288 [X] Pumped [ ] Poured
Type: 1/4" Gravel
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 307 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	300	15 min
23	390	15 min

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* ~~0073086~~ 30823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1957
Signed Larry Dailey by [illegible] (By driller performing actual drilling on site or contractor)
Date 7/6/2009

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY