

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 10862  
Permit No. \_\_\_\_\_  
Basin 176

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61097

1. OWNER Bald Mountain Mine ADDRESS AT WELL LOCATION Bald Mountain  
MAILING ADDRESS PO Box 5279 MW-03  
Elko, NV 89802 Subdivision Name: \_\_\_\_\_ County: White Pine

2. LOCATION NW 1/4 NW 1/4 Sec 29 T 24N N/S R 58 E Latitude 39 55'22.02"N UTM E  NAD 27  
PERMIT/WAIVER No. NEV0098100 Longitude 115 28'15.02"W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium	No	0	50	50
1.5" PVC Lysimeter Cup		+2	48	50
Neat Cement		0	2	2
Back Fill w/Cuttings		2	44	42
1/4" Gravel		44	46	2
200 Mesh Silica Flour		46	50	4

9. WELL CONSTRUCTION

Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>14</u>	<u>0</u>	<u>6</u>		
<u>6</u>	<u>6</u>	<u>50</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.5</u>		<u>Sch 40 PVC</u>	<u>+2</u>	<u>48</u>

Perforations: \_\_\_\_\_  
Type of perforation None  
Size of perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 6  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 46  Pumped  Poured  
Type: 200 Mech Silica Flour #8 from 46' to 44" (see Lithological section for detail)  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 8-May , 20 09  
Date completed: 13-May , 20 09

7. Water Level  
Static water level: Dry feet below land surface  
Artesian Flow: No G.P.M. N/A P.S.I.  
Water Temperature: None °F  
Quality: None

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Nevada Contractor  
Address PO Box 2748 Contractor  
Elko, NV 89803

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0073086 30823

Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1957

Signed Larry Bailey  
By driller performing actual drilling on site or contractor

Date 5/13/2009