STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108677
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32257

1. OWNER Miller Sally Anne
MAILING ADDRESS 1600 N. Decatur Blvd
Las Vegas, NV, 89108

ADDRESS AT WELL LOCATION Same as Owner
B-23/MW-12
Subdivision Name: County: clark

2. LOCATION SW ¼ SW ¼ Sec 19 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-19-401-006
Issued by Water Resources Parcel No.

Latitude 36.11'18.38"
Longitude 115.12'20.26"
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	3	3
Caliche		3	5	2
Silty Sand		5	13	8
Silt		13	14	1
Caliche		14	19	5
Silt		19	26	7
Silt w/ Sand		26	30	

Date started: 12-Jun , 20 09
Date completed: 16-Jun , 20 09

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	28	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.06	Sch 40	0	28

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 8 feet to 28 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 6 to 30 [ ] Pumped [X] Poured
Type: # 3 Silica
Bentonite Chips: [X] Yes [ ] No 1 to 6 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 15.42 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells
Contractor
Address 570 corinthian way
Contractor
N Las Vegas 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ M-2381
Signed
By driller performing actual drilling on site or contractor
Date 6-29-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY