STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108713
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34239

1. OWNER ACE CAB INC.
MAILING ADDRESS 5010 S. VALLEY VEIW BLVD. LAS VEGAS NV. 89118
ADDRESS AT WELL LOCATION 5010 S. VALLEY VEIW BLVD. LAS VEGAS NV. 89118
Subdivision Name: County: CLARK

2. LOCATION NW/4 NW/4 Sec 29 T 21 N/S R 61 E
Latitude 36° 05.935 N
Longitude 115. 11. 276 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. Issued by Water Resources
162.29.101.043 Parcel No.

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0.0	.25	.25
STONE+SAND BASE		.25	1.0	.75
SILTY SAND		1.0	4.0	3.0
CALICHE		4.0	12.5	8.5
SILTY SAND WITH STONE	YES	12.5	34.0	21.5
CALICHE		34.0	35.0	1.0

FACILITY I.D. NUMBER B-000204

DCNR/DWR RECEIVED JUN 09 2009 LAS VEGAS OFFICE

Date started: 6-1, 20 09
Date completed: 6-1, 20 09

7. Water Level
Static water level: 27.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	35	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	35

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020.
From 20 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to	☐ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☒ Concrete Grout	0 to 1	☐ Pumped	☒ Poured
☒ ≥30% Bentonite Grout	1 to 18	☐ Pumped	☒ Poured

Gravel Pack: ☒ Yes ☐ No 18 to 35 ☐ Pumped ☒ Poured
Type: 2x16
Bentonite Chips: ☒ Yes ☐ No 16 to 18 ☐ Pumped ☒ Poured
Type: 3/8" SEAL ABOVE SAND PACK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST LAS VEGAS NV. 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-8-2009

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627