

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 108714  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34239

1. OWNER ACE CAB INC ADDRESS AT WELL LOCATION 5010 S. VALLEY VIEW BLVD. LAS VEGAS NV 89118  
MAILING ADDRESS 5010 S. VALLEY VIEW BLVD. LAS VEGAS NV 89118 Subdivision Name: \_\_\_\_\_ County: CLARK  
2. LOCATION NW 1/4 NW 1/4 Sec 29 T 21 N/S R 61 E Latitude 36° 05.936 N. UTM E  NAD 27  
PERMIT/WAIVER No. 162-29-101-043 Longitude 115° 11.273 W. N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other USA.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0.0	1.25	1.25
SAND+STONE BASIC		1.25	1.0	1.75
SILT SAND		1.0	5.5	4.5
CAUCHE		5.5	13.0	7.5
SILT SAND WITH SILT	YES	13.0	34.0	21.0
CAUCHE		34.0	35.0	1.0

FACILITY ID. NUMBER  
8-000204

**DCNR/DWR RECEIVED**  
JUN 09 2009

**LAS VEGAS OFFICE**

9. WELL CONSTRUCTION  
Depth Drilled 35 Feet Depth Cased 35 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
8 Inches 0 Feet 35 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SC40</u>	<u>10</u>	<u>35</u>

Perforations:  
Type of perforation MACHINE FEED  
Size of perforation .020  
From 20 feet to 35 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	_____ to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	_____ to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	<u>0</u> to <u>1</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	<u>1</u> to <u>18</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured

Gravel Pack:  Yes  No 18 to 35  Pumped  Poured  
Type: 2X16

Bentonite Chips:  Yes  No 16 to 18  Pumped  Poured  
Type: 3/8" SEAL ABOVE SAND PACK

Date started: 6-1 20 09  
Date completed: 6-1 20 09

7. Water Level  
Static water level: 27.2 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE DRILLING Contractor  
Address 7150 PLACID ST. LAS VEGAS NV. 89119 Contractor  
Nevada contractor's license number 51266 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357  
Signed Matt Walker  
By driller performing actual drilling on-site or contractor  
Date 6-8-2009