WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108722
Permit No.
Basin

NOTICE OF INTENT NO. 33187

1. OWNER CHARLES W DAY & WARREN,LEE ANN
MAILING ADDRESS 1890 N SHARON ST.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1890 N SHARON ST.

2. LOCATION NE 1/4 NE 1/4 Sec. 4 T 20S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources | 35-051-18 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0	11	11
CALICHE		11	18	7
CLAY		18	38	20
CALICHE		38	65	27
CLAY		65	85	20
CALICHE	WB	85	95	10
CLAY		95	110	15
CALICHE	WB	110	125	15
CLAY		125	142	17
CALICHE	WB	142	156	14
CLAY		156	170	14
CALICHE	WB	170	185	15
CLAY		185	193	8
CALICHE	WB	193	200	7

N 36° 14' 50.0"
W 116° 01' 05.4"

DCNR/DWR
RECEIVED
AUG 28 2009
LAS VEGAS OFFICE

Date started 8/20/2009 , 19__
Date completed 8/20/2009 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 8/24/2009

USE ADDITIONAL SHEETS IF NECESSARY