STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108737
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32420

1. OWNER 7-Eleven Inc %AV Tax Dept#29662
MAILING ADDRESS P.O. Box 711
Dallas, TX 75221-0711

ADDRESS AT WELL LOCATION 601 N. Eastern Ave
MW-3
Las Vegas
Subdivision Name: County: clark

2. LOCATION SE ¼ SE ¼ Sec 26 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-26-801-003
Issued by Water Resources Parcel No.

Latitude 36.174198
Longitude 115.11478
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	4	4
Fine Sand		4	5	1
Sand		5	14	9
Caliche		14	20	6
Clay		20	30	10

Date started: 4-Aug, 20 09
Date completed: 4-Aug, 20 09

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.06	Sch 40	0	30

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 8 to 30 [ ] Pumped [X] Poured
Type: # 3 Silica
Bentonite Chips: [X] Yes [ ] No 1 to 8 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells (Contractor)
Address 570 corinthian way (Contractor)
N Las Vegas 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 9-1-09

DCNR/DWR RECEIVED
SEP 04 2009
LAS VEGAS OFFI

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY