STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108740
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32270

1. OWNER Pro Logis
MAILING ADDRESS 3250 W Ali Baba Lane
Las Vegas, NV

ADDRESS AT WELL LOCATION Same as Owner
B-2
Subdivision Name: County: clark

2. LOCATION SE ¼ NW ¼ Sec 29 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-29-202-008
Issued by Water Resources Parcel No.

Latitude 36.09578
Longitude 115.13265
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Cemented Gravel		2	4	2
Clayey sand		4	7	3
Silty Sand		7	9	2
Sandy Clay		9	11	2
Caliche		11	13	2
Sand w/ Gravel		13	15	2
Sand w/ Silt		15	18	3
Clayey Sand		18	20	2
Cemented Gravel		20	23	
sand w/ Gravel		23	28	5
Clay		28	30	
Sandy Clay		30	43	13

Date started: 18-Jun , 20 09
Date completed: 18-Jun , 20 09

9. WELL CONSTRUCTION
Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	43	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.70	Sch 40	0	43

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 28 feet to 43 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 26 to 43 [ ] Pumped [X] Poured
Type: # 3 Silica
Bentonite Chips: [X] Yes [ ] No 1 to 26 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 31 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells
Contractor
Address 570 corinthian way
Contractor
N Las Vegas 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ M-2381
Signed
By driller performing actual drilling on site or contractor
Date 6-30-09

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY