STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108742
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32270

1. OWNER Pro Logis
MAILING ADDRESS 3250 W Ali Baba Lane
Las Vegas, NV

ADDRESS AT WELL LOCATION Same as Owner
B-1
Subdivision Name: County: clark

2. LOCATION SE ¼ NW ¼ Sec 29 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-29-202-008
Issued by Water Resources Parcel No.

Latitude 36.09571 N
Longitude 115.18336W
UTM E N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Caliche		2	3	1
Sand w/ Silt		3	5	2
Silty Sand		5	8	3
Sandy Lean Clay		8	9	1
Cemented Gravel		9	11	2
Sand w/ Gravel		11	15	4
Sand w/ Silt-Partially Cemented		15	17	2
Clayey sand		17	24	7
Sand w/Silt		24	25	
Sandy Clay		25	45	20

Date started: 18-Jun, 20 09
Date completed: 18-Jun, 20 09

9. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	45	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.70	Sch 40	0	41

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 29 feet to 41 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 27 to 45 [ ] Pumped [X] Poured
Type: # 3 Silica
Bentonite Chips: [X] Yes [ ] No 1 to 27 [ ] Pumped [X] Poured
Type: 3/8 chips

7. Water Level
Static water level: 31 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells (Contractor)
Address 570 corinthian way (Contractor)
N Las Vegas 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 6-30-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

JUL 0 2 2009
LAS VEGAS OFFICE