

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32227

1. OWNER John J. & Sam Dudek ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6970 Smoke Ranch Rd \_\_\_\_\_  
Suite 150 LV, NV 89128 \_\_\_\_\_  
 2. LOCATION SW 1/4 NW 1/4 Sec 07 T 19 N/S R 57 E CLARK County  
 PERMIT NO. 128-07-201-003 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>2</u>	
<u>Gray Lime Stone</u>		<u>2</u>	<u>20</u>	
<u>Brown " "</u>		<u>20</u>	<u>30</u>	
<u>Limestone &amp; Quartz</u>		<u>30</u>	<u>50</u>	
<u>Black Limestone</u>		<u>50</u>	<u>150</u>	
<u>Cream " "</u>		<u>150</u>	<u>248</u>	
<u>Black " "</u>	<u>X</u>	<u>248</u>	<u>250</u>	
<u>Cream " "</u>		<u>250</u>	<u>255</u>	
<u>Black " "</u>		<u>255</u>	<u>260</u>	
<u>Cream " "</u>		<u>260</u>	<u>265</u>	
<u>Black " "</u>	<u>X</u>	<u>265</u>	<u>285</u>	
<u>Cream " "</u>		<u>285</u>	<u>300</u>	
<u>Black " "</u>	<u>X</u>	<u>300</u>	<u>303</u>	

N 36° 18' 54" "  
W 115° 37' 58" "

8. WELL CONSTRUCTION  
 Depth Drilled 303 Feet Depth Cascd. 303 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 1/4 Inches 0 Feet 303 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>Schd. 80</u>	<u>PVC</u>	<u>-3</u>	<u>100</u>
<u>8 5/8</u>	<u>16.97</u>	<u>.188</u>	<u>12</u>	<u>3</u>
<u>6 1/2</u>	<u>Schd. 40</u>	<u>PVC</u>	<u>0</u>	<u>303</u>

Perforations:  
 Type perforation DRILL  
 Size perforation 3/8" 4 Times Around  
 From 251 feet to 303 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 06-03-09, 20\_\_\_\_\_  
 Date completed 06-20-09, 20\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

JUN 23 2009

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 5360 N. Bonito Vista St  
LV, NV 89149 Contractor  
 Nevada contractor's license number 210062  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 552  
 Division of Water Resources, the on-site driller  
 Signed V.H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 06-23-09