WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108744
Permit No.
Basin 212

NOTICE OF INTENT NO. 34760

1. OWNER LIOLIADIS FAMILY TRUST
MAILING ADDRESS 5285 N. DAPPLE GRAY RD LV. NV. 89149
ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ NW ¼ Sec. 32 T. 19 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources) 125-32-205-002 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DRILLOUT OLD CASING | | 290 | 400 | |
| GRAVEL | | 400 | 485 | |
| GRAVEL + WATER | | 485 | 508 | |
| N 36-15-26.0 | | | | |
| W 115-17-42.0 | | | | |

Date started 06-24-09, 20
Date completed 06-25-09, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 508 Feet Depth Cased 508 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 7 7/8 | 400 | 508 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | PVC | Sch 40 | +1 | 508 |
| | | | | |

Perforations:
Type perforation Drilled
Size perforation 3/8" x 4 Times Around
From 458 feet to 508 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal Deepening
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON H. DIMICK (Contractor)
Address 5360 N. BONITA VISTA ST (Contractor)
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 07-06-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627