STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108746
Permit No.
Basin 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32097

1. OWNER PETE SWAN
MAILING ADDRESS HC 72 Box 8694 DYER NV 89010
ADDRESS AT WELL LOCATION VALLEY CENTER RD. HC 72 Box 8694 DYER NV. 89010
Subdivision Name: County: ESMERALDA

2. LOCATION SE ¼ NE ¼ Sec 22 T 3 N OR 35 E
PERMIT/WAIVER No. 007-311-08 Issued by Water Resources Parcel No.
Latitude 37° 39' 927 Longitude 118° 04' 274
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition ☑ Deepen ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CEMENTED ROCK + GRAVEL		143	146	3
SAND	W.B.	146	161	15
COARSE SAND + GRAVEL 3/8"		161		
WITH COBBLES	W.B.		290	129

DCNR/DWR RECEIVED SEP 02 2009 LAS VEGAS OFFICE

Date started: 8-24, 20 09
Date completed: 8-28, 20 09

9. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8"	Inches	143 Feet	290 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½"	2.37	PVC .248	290	surface

Perforations:
Type of perforation FACTORY SCREEN
Size of perforation .020 inch x 3" inch
From 284 feet to 264 feet
From 244 feet to 224 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No EXISTING
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☑ Yes ☐ No 290 to 0 ☐ Pumped ☑ Poured
Type: PEA GRAVEL
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 130 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOL °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. Contractor
Address P.O. Box 3505 Pahrump NV 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed By driller performing actual drilling on-site or contractor
Date 8-28-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627