

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348



Log No. _____
 Permit No. _____
 Basin. **289**

NOTICE OF INTENT NO. **61759**

1. OWNER Jay & Marjorie Wright ADDRESS AT WELL LOCATION 25 miles East of Alamo on Hwy. 93 & back West 3 miles on dirt road.
 MAILING ADDRESS 4268 North 1900 East Buhl, ID 83316

2. LOCATION NW 1/4 SE 1/4 Sec. 15 T 4 R 61 E Lincoln County
 PERMIT NO. 70509 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cemented Alluvial Sand & Gravel		0	170	170
Sand Stone		170	350	180
Volcanic Type Sandstone		350	700	350
Fractured Volcanic Sandstone	x	700	710	10
Volcanic Sandstone		710	760	50
Fractured Volcanic Sandstone	x	760	765	5
Volcanic Sandstone		765	806	41

Handwritten notes:
 37.597723°N
 115.125149°W NAD 2011 (TA)

WGS 84
 Lat. N37°, 35', .861"
 Long. W115°, 07', .56"
 Elevation 4,297

8. WELL CONSTRUCTION
 Depth Drilled 806 Feet Depth Cased 806 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 806 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	806

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 Rows
 From 680 feet to 806 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 806 feet

9. WATER LEVEL
 Static water level 665 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Ave. Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis, By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date February 26, 2009

Date started December 16, 2008
 Date completed January 15, 2009

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>100</u>	<u>135</u>	<u>2</u>	