STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108879
Permit No.
Basin 087

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64424

1. OWNER Glenn Anderson
MAILING ADDRESS 501 Hobbs Wall
Cresent City Ca. 95531

ADDRESS AT WELL LOCATION 4650 Mt. Rose Hwy
Reno
Subdivision Name: County: Washoe

2. LOCATION SE¼SW¼ Sec25T18N/ R19E
PERMIT/WAIVER NO. DOM09-008 (Issued by Water Resources) 150-022-04 (Parcel. No.)

Latitude 39.39001 UTM E ☐ NAD 27
Longitude 119.79940 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	14	13
Volcanic rock weatherd		14	46	32
Gray volcanic rock		46	86	40
Brown volcanic rock		86	196	110
Weatherd granite		196	246	50
Fracture	x	246	247	1
Weatherd granite		247	281	34
Fracture	x	281	283	2
Weatherd granite		283	296	13

Washoe Permit WL090060

39.390099°N
119.790379°W
NAD 27
TA

Date started: 6/24/09, 20
Date completed: 6/26/09, 20

9. WELL CONSTRUCTION
Depth Drilled 296 Feet Depth Cased 296 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
8 1/2 Inches	100 Feet	296 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	296

Perforations:
Type of perforation Factory
Size of perforation 3/32 x 3

From 236 feet to 256 feet
From 276 feet to 296 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 100	☐ Pumped	☒ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 296 ☐ Pumped ☐ Poured
Type: 1/4 x 1/8
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 168 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality: Not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 6/26/09

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com