WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108995
Permit No.
Basin 29139

NOTICE OF INTENT NO. 33189

1. OWNER VICTORIA CAPITAL CORP
MAILING ADDRESS BEATTY
BEATTY, NV

ADDRESS AT WELL LOCATION BEATTY

2. LOCATION SE 1/4 NE 1/4 Sec. 19 T 12S N/S R 47E E NYE County
PERMIT NO. 29139 Issued by Water Resources
18-371-15 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PREFORATE WELL FROM				
125 TO 30FT, WITH				
MILLS KNIFE. HIT				
CEMENT SEAL AT 30FT.				
PREFS ARE 1/2 INCH BY				
3 INCH 6 ROWS EACH 2				
LINER FT. PUMPED 90				
CU.FT OF NEAT CEMENT				
FROM 125 TO SURFACE				
THROUGH 1 1/4 INCH				
TRIMI PIPE				
N 36° 52.820				
W 116° 45.363				

Date started 9/23/2009 , 19__
Date completed 10/5/2009 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
OCT 20 2009
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 9/23/2009 Feet Depth Cased 10/05/20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EST 10"	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXST 10"			0	126

Perforations:
Type perforation MILLS KNIFE
Size perforation 1/2 X 3
From 125 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 10/5/2009

USE ADDITIONAL SHEETS IF NECESSARY