

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 109027
 Permit No. _____
 Basin φ 71
 NOTICE OF INTENT NO. 65097

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Ken Goslin** ADDRESS AT WELL LOCATION **9155 Betty Lane**
 MAILING ADDRESS **9155 Betty Lane** **Winnemucca, NV 89445**
 Subdivision Name: _____ County: **Humboldt**

2. LOCATION **NW 1/4 NW 1/4 Sec 30 T35N R38E** Latitude **N40°53.115** UTM E _____ NAD 27
 PERMIT/WAIVER NO. **N/A** Parcel No. **010-532-03** Longitude **W117°45.173** N _____ NAD 83/WGS 84
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/Clay		0	7	7
Boulder/cobles		7	50	43
Clay/sand		50	70	20
Cobles		70	100	30
Gravel		100	115	15
Clay/cobles		115	125	10
Sand/gravel		125	140	15
Clay		140	160	20
Cobles/gravel	X	160	180	20
Clay		180	205	25
Cobles/gravel/sand	X	205	255	50
Clay		255	260	5

40.885346° N
 117.751920° W
 NAD 83
 (TA)

9. WELL CONSTRUCTION

Depth Drilled **260** Feet Depth Cased **260** Feet

HOLE DIAMETER (BIT SIZE)

From	To
11 Inches	0 Feet 260 Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	20	+1
6.625	4.06	.316	20	260

Perforations:

Type of perforation **Factory Cut Slots**
 Size of perforation **050**

From **220** feet to **260** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 50 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 55 to 260 Pumped Poured
 Type: _____
 Bentonite Chips: Yes No 55 to 50 Pumped Poured
 Type: _____

Date started: **October 1, 20 09**
 Date completed: **October 7, 20 09**

7. Water Level

Static water level: **176** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	Draw Down	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. 30 (Feet Below Static) _____		5
15		
25		
30		

2009 OCT 16 AM 11:52

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
 Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**
 Signed *Fred Anderson Drilling Inc*
 By driller performing actual drilling on site of contractor
 Date **October 14, 2009**