


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY 109040

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK
NEV-50052

1. OWNER **PIOCHE PUBLIC UTILITIES**
 MAILING ADDRESS **EAGLE VALLEY RD. & US HWY 93**
PIOCHE, NV

ADDRESS AT WELL LOCATION **EAGLE VALLEY RD. & US HWY 93**

2. LOCATION **SW 1/4 SW 1/4 Sec. 14 T 1**
 PERMIT NO. **001-210-13**
 Issued by Water Resources Parcel No.

N/S R **67 E** **LINCOLN** County
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & GRAVEL		0	40	40
ROCK		40	50	10
LEAK DETECTON WELL N 37°56' 29" W 114° 26'42"				
FACILITY ID # NEV 50052				
<u>37.941426°N</u>				
<u>114.444175°W</u>				
<u>NAD 27 (TA)</u>				

8. WELL CONSTRUCTION
 Depth Drilled **50** Feet Depth Cased **50** Feet
 HOLE DIAMETER (BIT SIZE)
 From **10** Inches To **0** Feet
 From **0** Feet To **50** Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	1.96	.237	0	50

Perforations:
 Type perforation **SLOTTED**
 Size perforation **2X020**
 From **30** feet to **50** feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **29**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From **29** feet to **50** feet
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Bentonite

9. WATER LEVEL
 Static water level No water feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started **10/13/2009**
 Date completed **10/16/2009**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
 Contractor

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

STATE ENGINEERS OFFICE
 2009 OCT 22 AM 11:06
 RECEIVED

Address **1220 E MANSE RD**
 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date **10/19/2009**