STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109063
Permit No.
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65125

1. OWNER Dustin & Brittney Hendrix
MAILING ADDRESS POB 248
SE Lund, NV 89317

ADDRESS AT WELL LOCATION 239 N. 100 E.
Lund, NV 89317
Subdivision Name: Lund Townsite County: White Pine

2. LOCATION NW ¼ ~~NE~~ ¼ Sec ~~35~~ 28 T 12N N/S R 62 E
PERMIT/WAIVER No. 28 (Issued by Water Resources) APN 006-015-12 Parcel No.

Latitude N38, 51', 77.9"
Longitude W115, 00', 33.8"
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ ~~New Well~~ ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Course Sand & Gravel		3		
w/ Clay Stringers			20	17
Cemented Sand & Gravel		20	35	15
Sand & Gravel		35	55	20
Gravel w/ Clay Stringers		55	65	10
Course Water Gravel	x	65	70	5
Sand & Gravel		70	105	35
Course Water Gravel	x	105	115	10
Course Gravel & Clay		115	130	15
Brown Clay		130	137	7

2009 OCT 27 AM 10:47 STATE ENGINEER'S OFFICE

38.872°N NAD27DD
115.009°W

Date started: Oct. 9, 20 09
Date completed: Oct. 14, 20 09

9. WELL CONSTRUCTION
Depth Drilled 137 Feet Depth Cased 137 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	137	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	17.02	.250	0	137

Perforations:
Type of perforation Torch
Size of perforation 5/32" x 8" 6 Rows
From 61 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 50' ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 137 ☐ Pumped ☒ Poured
Type: 3/8" Pea Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 56 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45	79	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the *State Contractor's Board* 14790
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1793
Signed Rich Lewis By Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date 23-Oct-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY