WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109067
Permit No.
Basin Ø56

NOTICE OF INTENT NO. 64886

1. OWNER Reese River Ranches
MAILING ADDRESS P.O. Box 503, 103 Main St, Austin, Nev 89310
ADDRESS AT WELL LOCATION Lot 1 Reese River Ranches

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 18 N/ R. 42 E. Lander County
PERMIT NO. (Issued by Water Resources) Parcel No. Lot #1 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	
Gravel		2	05	
Clay + Sand		05	70	
Gravel + Water	x	70	75	
Sand + Water	x	75	150	

N 39° 23 [illegible] .917 +
W 117° 17 #. 990 Nad 27

39.399°N NAD27 D.D.
117.300°W

RECEIVED 2009 OCT 23 AM 11:52 STATE ENGINEER'S OFFICE

Date started 08-13-09, 20
Date completed 09-16-09, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	50 Feet
9⅞ Inches	50 Feet	150 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	16.94	.188	+2	150

Perforations:
Type perforation Torch
Size perforation 1/4 x 8" x 4 Times
From feet to feet
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H Dimick (Contractor)
Address 5360 N. Bonita Vista St (Contractor)
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 09-29-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627