

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64883

1. OWNER Reese River Ranch ADDRESS AT WELL LOCATION LOT 61  
 MAILING ADDRESS P.O. Box 503, 103 Main St. Austin, Nev. 89310 Reese River Ranch  
 2. LOCATION SE 1/4 NW 1/4 Sec 30 T 18 N 42 E LANDER County  
 PERMIT NO. \_\_\_\_\_ Parcel No. LOT # 61 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	2	
GRAVEL		2	20	
SAND & CLAY		20	75	
GRAVEL + WATER	X	75	90	
SAND		90	120	
GRAVEL + SAND		120	148	

N 39-23-844  
 W 117-17-991 NAD 27

39.397°N NAD 27 P.D.  
 117.300°W

2009 OCT 23 AM 11:52  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 148 Feet Depth Cased 148 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 148 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>148</u>

Perforations:  
 Type perforation Torch  
 Size perforation 1/8" x 6" x 4 Times  
 From 143 feet to 148 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 48 feet to 148 feet

9. WATER LEVEL  
 Static water level Cold 78 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 5360 N. Bonita Vista St Contractor  
LV. NV. 89149  
 Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552  
 Signed V.H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 09-29-09

Date started 09-01-09, 20 \_\_\_\_\_  
 Date completed 09-16-09, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)