

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109070
Permit No. _____
Basin φ56

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Reese River Ranches ADDRESS AT WELL LOCATION LOT 2 Reese River Ranches, AUSTIN, NEV. 89310
MAILING ADDRESS P.O. Box 503, 103 MAIN ST AUSTIN, NEV. 89310 Subdivision Name: _____ County: LAUREL
2. LOCATION 5E NW 1/4 Sec 30 T 18 N R 42 E Latitude N 39-23.0 828 UTM E NAD 27
PERMIT/WAIVER No. _____ Longitude W 117-18.0 015 N NAD 83/WGS 84
Issued by Water Resources Parcel No. LOT # 2 Reese River Ranches

NOTICE OF INTENT NO. 64884

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	2	
GRAVEL		2	20	
SANDS GRAVEL		20	75	
GRAVEL + water X		75	90	
SAND		90	120	
GRAVEL-SAND-WATER X		120	147	

39.317°N NAD 27 DD.
117.300°W

9. WELL CONSTRUCTION

Depth Drilled 147 Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
12 1/4	0	50	Feet
9 7/8	50	147	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	16.94	.188	+2	147

Perforations:

Type of perforation Torch

Size of perforation 1/4 x 8" x 4 TIMES AROUND

From 117 feet to 147 feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout to _____ Pumped Poured

Concrete Grout 0 to 50 Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 50 to 150 Pumped Poured

Type: PCA ROCK

Bentonite Chips: Yes No to _____ Pumped Poured

Type: _____

Date started: 08-15-09, 20
Date completed: 09-16-09, 20

7. Water Level

Static water level: 54 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: Cold °F

Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON A Dimich Contractor

Address 5360 N. BONITA VISTA ST. LV. NV. 89149

Nevada contractor's license number 10062

issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources the on-site driller 552

Signed V.H. Dimich By driller performing actual drilling on-site or contractor

Date 10-05-09