

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109071
Permit No. _____
Basin φ56

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64885

1. OWNER Reese River Ranches ADDRESS AT WELL LOCATION Lot 62 Reese River Ranches Austin, Nev. 89310
MAILING ADDRESS Box 503, 103 Main St, Austin, Nev. 89310 Subdivision Name: Lot 62 County: Lander
2. LOCATION SE NW 1/4 Sec 30 T 18 N/S R 42 E Latitude N 39-23-847 UTM E NAD 27
PERMIT/WAIVER NO. Lot 62 Longitude W 117-17-990 N NAD 83/WGS 84
Issued by Water Resources Parcel No. Lot 62 Reese River Ranches

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	2	
Gravel		2	20	
Sand + clay		20	25	
Gravel Water	X	25	90	
Sand		90	120	
Shallow Sands Water	X	120	140	

39.397°N NAD27 P.O.
117.300°W

2009 OCT 28 AM 11:52
STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>12 1/4</u>	0	50	Feet
<u>9 7/8</u>	50	140	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>140</u>

Perforations:

Type of perforation Torch

Size of perforation 1/4 x 8" x 4 Times

From 13.5 feet to 140 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement _____ to _____ Pumped Poured

Cement Grout _____ to _____ Pumped Poured

Concrete Grout 0 to 50 Pumped Poured

≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 50 to 140 Pumped Poured

Type: Pea Rock

Bentonite Chips: Yes No _____ to _____ Pumped Poured

Type: _____

Date started: 09-05-09, 20
Date completed: 09-16-09, 20

7. Water Level

Static water level: 60 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: Cold °F

Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor

Address 5360 N. Bonita Vista St. LV. NV. 89149 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10062

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed VH Dimick By driller performing actual drilling on-site or contractor

Date 09-16-09