Facility ID #
NDEP #4-000356

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109076
Permit No.
Basin 085

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62920

1. OWNER BERRY-HINCKLEY INC
MAILING ADDRESS 8995 LA POSADA DR. SPARKS, NV

ADDRESS AT WELL LOCATION 8995 LA POSADA DRIVE SPARKS, NV
N/A WASHOE
Subdivision Name: County:

2. LOCATION SW ¼ SW ¼ Sec 35 T 21N N/S R 20 E
PERMIT/WAIVER No. 534-092-04
Issued by Water Resources Parcel No.

Latitude 39.63892
Longitude 119.71046
UTM E
N
[X] NAD 27 (1A)
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GROUND SURFACE				
ASPHALT		0	.5	1
FILL MATERIAL		.5	3	3
SILTY CLAY		3	6	3
SILTY SAND		6	23	17
SILT		23	32	9
SILTY SAND		32	50	18
POORLY GRADED SAND		50	53	3
SILTY CLAY		53	55	2

Date started: 3-24 .2009
Date completed: 3-24 .2009

9. WELL CONSTRUCTION
Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7	Inches	0	Feet	55	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1		SCH 40	.5	50

Perforations:
Type of perforation SLOTTED
Size of perforation 0.01
From 50 feet to 52 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [✓] Yes [ ] No
[X] Neat Cement 1 to 47 [✓] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 49 to 52 [✓] Pumped [ ] Poured
Type: 2/12 MONTEREY SAND
Bentonite Chips: [X] Yes [ ] No 47 to 49 [ ] Pumped [✓] Poured
Type: 3/8 CHIPS

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PC EXPLORATION INC. (Contractor)
Address 2905 LESVOS COURT LINCOLN, CA 95648 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0028767
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2223
Signed (By driller performing actual drilling on site or contractor)
Date 10/28/2009

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

2009 NOV -6 AM 11:49 STATE ENGINEER'S OFFICE