


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 109111
Permit No. 164
Basin pg/052



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62647

1. OWNER Parks Dept, Carson City ADDRESS AT WELL LOCATION 601 Old Clear Creek Rd
MAILING ADDRESS 3303 Butti Way, #9 Carson City, NV 89705
Subdivision Name: Fuji Park Pond County: Carson City

2. LOCATION SE 1/4 SE 1/4 Sec 31 T 15N N/S R 20 E Latitude 39 06'53.12" UTM E NAD 27
PERMIT/WAIVER No. DEW-80 1520-009-303-003 Longitude 119 46'25.89" N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Residential
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See Attached				
<u>#1</u>				
<u>39.114847°N</u>				
<u>119.772845°W</u>				
<u>NAD 27 (A)</u>				
<u>PLUGGED BY NWT #62648</u>				
<u>See plugging log</u>				
<u>#109891</u>				

9. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>24</u> Inches	<u>0</u> Feet	<u>40</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>3/8</u>	<u>0</u>	<u>40</u>

Perforations:

Type of perforation machine slot
Size of perforation 0.032

From	feet to	feet	feet
<u>20</u>	<u>40</u>		

Annular Seal: Yes No

Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout 10 to 12 Pumped Poured

Gravel Pack: Yes No 12 to 40 Pumped Poured
Type: 3/8 Pea Gravel

Bentonite Chips: Yes No 10 to 12 Pumped Poured
Type: 3/8's

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Viking Drillers Inc Contractor
Address 801 Northport Dr. Contractor
West Sacramento, CA

Nevada contractor's license number
issued by the State Contractor's Board 0034680

Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M-2091

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11/4/09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER. LOG # 109111 PA 2012

LOG FOR BORING NO. <u>#1A</u>		JOB NAME: <u>F&P Construction</u>			
DATE STARTED <u>9/30/09</u>	DATE COMPLETED <u>9/30/09</u>	LOGGED BY <u>EB</u>	DRILLED BY <u>EB</u>	TYPE OF DRILL RIG <u># 32</u>	JOB NO. <u>5967</u>
DEPTH OF HOLE <u>40'</u>	DIAMETER OF HOLE <u>4" 24"</u>	CASING <u>8"</u>	PERFORATIONS <u>20'</u>	SAMPLING METHOD	ELEVATION
LOCATION				DRILLERS NOTES:	

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
0'			Brown silty sand
10'			gray sand - tight. med.
20'			SAND & Cobbles Tight.
30'			
40'			
50'			
60'			
70'			
80'			
90'			
100'			

RECEIVED
2009 NOV -6 PM 12:02
STATE ENGINEERS OFFICE